

NYISO Gold Book Coincident Summer Peak and Winter Peak Average Demand by Zone - MW

Period	Parameter	A	B	C	D	E	F	G	H	I	J	K	NYCA
98 - 02	Summer	2,605	1,676	2,592	721	1,287	2,036	2,196	460	1,278	10,148	4,651	29,651
	Winter	2,445	1,449	2,470	873	1,323	1,876	1,669	387	898	7,165	3,233	23,789
	Ratio	1.07	1.16	1.05	0.83	0.97	1.09	1.32	1.19	1.42	1.42	1.44	1.25
13 - 17	Summer	2,504	1,876	2,714	593	1,344	2,216	2,146	633	1,384	10,733	5,187	31,330
	Winter	2,328	1,576	2,656	729	1,371	1,931	1,588	530	933	7,574	3,375	24,590
	Ratio	1.08	1.19	1.02	0.81	0.98	1.15	1.35	1.19	1.48	1.42	1.54	1.27
26 - 30	Summer	2,747	1,982	2,742	712	1,247	2,255	2,116	674	1,451	11,293	5,252	32,470
	Winter	2,212	1,490	2,567	882	1,283	1,890	1,549	499	888	7,275	3,278	23,812
	Ratio	1.24	1.33	1.07	0.81	0.97	1.19	1.37	1.35	1.63	1.55	1.60	1.36